

Test Report

No.SDHL250901687301HI-1

Date: Oct 17, 2025

Page 1 of 2

FOSHAN MEXYTECH CO.,LIMITED

ROOM 2-8,BUILDING B,TORCH INNOVATION PARK,JIHUA 2 ROAD, CHANCHENG, DISTRICT FOSHAN CITY,
GUANGDONG PROVINCE,CHINA

Sample Description : TIMBEX DECK

As above test item and its relevant information regarding to the submission are provided and confirmed by the applicant. SGS is not liable to either the test item or its relevant information, in terms of the accuracy, suitability, reliability or/and integrity accordingly.

Sample Receiving Date : Sep 09, 2025

Test Performing Date : Sep 17, 2025 to Sep 29, 2025

Test Performed : Selected test(s) as requested by applicant

Test Result Summary

No.	Test item	Test(s) Requested	Result(s)	Comments
1	Determination of withdrawal capacity of fasteners	EN 15534-1:2014+A1:2017 (E) Clause 7.6 & EN 13446:2002 (E)	Refer to next page(s)	/
For further details, please refer to the following page(s)				

Signed for and on behalf of
SGS-CSTC Standards Technical Services Co., Ltd. Shunde Branch



Peter Zhao
Authorized Signatory

Scan to see the report



SDHL250901687301HI-1
Verification:
check.sgsonline.com.cn



Unless otherwise agreed in writing, this document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <https://www.sgs.com/en/Terms-and-Conditions>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 30 days only.

Attention: To check the authenticity of testing /inspection report & certificate, please contact us at telephone: (86-755) 8307 1443, or email: CN.Doccheck@sgs.com

1-2/F., Building 1, European Industrial Park, No.1, Shunhe South Road, Wusha, Daliang, Shunde District, Foshan, Guangdong, China 528300 t (86-757)22805888 www.ssgsgroup.com.cn
中国·广东·佛山市顺德区大良街道办事处五沙社区居民委员会顺和南路1号欧洲工业园一号厂房首层、二层 邮编: 528300 t (86-757)22805888 sgs.china@sgs.com

Test Report

No.SDHL250901687301HI-1

Date: Oct 17, 2025

Page 2 of 2

Test Information:

Sample Description: See photo

1. Test item: Determination of withdrawal capacity of fasteners

Test method: EN 15534-1:2014+A1:2017 (E) Clause 7.6 & EN 13446:2002 (E)

Test condition:

Screw size: ST 4.2×38


Nail speed: (60 ± 30) s

Screw in depth: 30 mm

Test result:

Test results		Conclusion
Board surface (N)	2530	/
The withdrawal parameter (N/mm ²)	20.1	
Board edge (N)	2660	
The withdrawal parameter (N/mm ²)	21.1	

Photo Appendix:



Original sample

Remark:

1. Unless otherwise stated, the decision rule for conformity reporting is based on Binary Statement for Simple Acceptance Rule (w=0) stated in ILAC-G8:09/2019.
2. This test report is to supersede No. SDHL250901687301HI test report which was issued on Sep 29, 2025. And the original test reports (paper and electronic) are invalid.

End of Report



Unless otherwise agreed in writing, this document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <https://www.sgs.com/en/Terms-and-Conditions>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 30 days only.

Attention: To check the authenticity of testing /inspection report & certificate, please contact us at telephone: (86-755) 8307 1443, or email: CN.Doccheck@sgs.com

1-2/F., Building 1, European Industrial Park, No.1, Shunhe South Road, Wusha, Daliang, Shunde District, Foshan, Guangdong, China 528300 t (86-757)22805888 www.sgs.com.cn
中国·广东·佛山市顺德区大良街道办事处五沙社区居民委员会顺和南路1号欧洲工业园一号厂房首层、二层 邮编: 528300 t (86-757)22805888 sgs.china@sgs.com